

		49 CFR 192.473 External Corrosion Control: Interference Currents (a) Each operator whose pipeline system is subject to stray currents shall have in effect a continuing program to minimize the detrimental effects of such currents. (b) Each impressed current type cathodic protection system or galvanic anode system must be designed and installed so as to minimize any adverse effects on existing adjacent underground metallic structures.	
Rectifier Directory			
Date 8-15-2011		Location Map Attached <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
		Case Number 1108107	
General Data			
Company Chesapeake Energy		Contact Jedediah Foley	
Address 179 Chesapeake Dr Jane Lew, WV 26378		Office Phone 304-517-1416x86085	Cell Phone 304-406-4945
Rectifier/Ground Bed Location Selbyville Compressor Facility N 38.75275 W -80.26283			
County Upshur		Tax District	
Nearest Town or Municipality Selbyville		Property Owner Chesapeake Energy	
Rectifier Data			
Rectifier Designation / Description Selbyville Gas Gathering system; suction , discharge and station piping			
Rated Output 60 DC Volts		Operating Output 13.45 DC Volts	
30 DC Amps		1.19 DC Amps	
Date Output Taken 8-11-2011			
Ground Bed Description			
Location From Rectifier 190 Feet <input type="checkbox"/> North <input type="checkbox"/> Northeast <input checked="" type="checkbox"/> East <input type="checkbox"/> Southeast <input type="checkbox"/> South <input type="checkbox"/> Southwest <input type="checkbox"/> West <input type="checkbox"/> Northwest			
Type of Ground Bed Conventional	Number of Anodes 10	Type of Anodes 4x80 Graphite	Anode Spacing 10 Feet
Structure Protected			
Type of Structure Pipelines		Size	Length
Coating Type FBE	Remarks Ground Bed is located within the station fence		
Other Structures			
Companies that may be Affected		Columbia Gas Transmission	