



49 CFR 192.473 External Corrosion Control: Interference Currents
(a) Each operator whose pipeline system is subject to stray currents shall have in effect a continuing program to minimize the detrimental effects of such currents.
(b) Each impressed current type cathodic protection system or galvanic anode system must be designed and installed so as to minimize any adverse effects on existing adjacent underground metallic structures.

Rectifier Directory

Date 3/10/2009	Location Map Attached <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	Case Number 0903100
-------------------	--	------------------------

General Data

Company Hampshire Gas Company	Contact Hampshire Gas Company	
Address HC 79 Box 69A Romney WV 26757	Office Phone 304/822/5664	Cell Phone

Rectifier/Ground Bed Location Approx. 5 Miles East of Romney WV ,Located off McKee Hollow Rd..

County Hampshire	Tax District Sherman
Nearest Town or Municipality Augusta	Property Owner Carl Haines

Rectifier Data

Rectifier Designation / Description Observation Gas Well #14		
Rated Output 48 DC Volts	Operating Output 17 DC Volts	Date Output Taken 3/10/09
8 DC Amps	3.32 DC Amps	

Ground Bed Description

Location From Rectifier 686 Feet <input type="checkbox"/> North <input type="checkbox"/> Northeast <input checked="" type="checkbox"/> East <input type="checkbox"/> Southeast <input type="checkbox"/> South <input type="checkbox"/> Southwest <input type="checkbox"/> West <input type="checkbox"/> Northwest			
Type of Ground Bed Conventional	Number of Anodes 15	Type of Anodes 3 x 60 Klida	Anode Spacing 30 Feet

Structure Protected

Type of Structure Natural Gas Observation Well	Size 7"	Length 6530'
Coating Type Cement	Remarks please call Hampshire Gas if interference testing is desired 304/822/5664	

Other Structures

Companies that may be Affected None	